

Year:

Manufacture:

Model:

Size:

- ___ Egress windows; Minimum size 22" vertical or horizontal with 5 square feet minimum openable
- ___ Exits; Two required Single section 12' minimum distance center to center. Double section 20' mini
- ___ A. One exit within 35' of any bedroom doorway.
- ___ B. Exterior swing door require 28" x 74" clear opening. Sliding glass require 28" x 72" clear opening
- ___ Flame Spread; Walls and ceilings adjacent to or enclosing Furnace or water heaters not to exceed
- ___ Exposed interior finishes; Adjacent to cooking range not to exceed 50 flame spread. MHCSS 3280
- ___ Vertical clearance above range minimum 24" to combustibles. MHCSS 3280.204(e).
- ___ Smoke detectors; Located on wall between first bedroom and living room. In hall ways must be be
- ___ Solid-fuel-burning stoves/fireplaces; Must be listed for manufactured housing use and installed to
- ___ Electrical System; Must be tested for continuity to confirm proper bonding, test equipment for prop
- ___ Electrical system properly protected for required amperage. Aluminum conductors connected to d
- ___ Replacement furnaces and water heaters; vents, roof jacks, and chimney must be listed for manu
- ___ Furnaces and water heaters must be secured from displacement and accessible for service or rep
- ___ Fuel burning Furnaces and water heaters must be installed to provide complete separation of the
- ___ Water heater floor adequate for water heater support.
- ___ Roof snow load. # Information acquired by